

2013 Quality Drinking Water Report for Villanueva MDWCA

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuníquese con alguien que pueda traducir la información.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 12 of those contaminants, and found only 1 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Ground Water

Source water assessment and its availability

New Mexico Environment Department Drinking Water Bureau completed a Source Water Assessment for the Villanueva MDWCA system. Please contact the agency for more information at 1-877-654-8720.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

We encourage members of the community to attend monthly meetings held on the 3rd Monday of the month at the South San Ysidro Community Center/El Valle Water Alliance Office at 6:30PM. If you have any questions regarding your Water and water system feel free to contact the water operator Carlos Vigil at 505-206-0621 or simply call our office at 575-421-3892.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Source Water Protection Tips

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA’s Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network’s How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people “Dump No Waste - Drains to River” or “Protect Your Water.” Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Significant Deficiencies

2012 CCR due on 7/1/13. Submitted on 7/9/13 with corrections.

Lack of Operation and management plan. Corrected on 5/1/13

Lack of Emergency response Plan. Corrected 5/1/13

Lack of Governing docs. Corrected 5/1/13

Operator Info. Corrected 6/13/13

Give Operator Keys. Corrected 7/1/13

Lack of TC sampling plan. corrected on 8/23/13

Lack of Lead and Copper Sampling Plan. 8/23/13

Lack of Well info & Map. Corrected 8/27/13

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Villanueva MDWCA is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The next lead and copper test will be conducted in 2016.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

| | MCLG or | MCL, TT, or | Your | Range | Sample | | |
|--|------------|----------------|------|-------|--------|--|--|
|--|------------|----------------|------|-------|--------|--|--|

| <u>Contaminants</u> | <u>MRDLG</u> | <u>MRDL</u> | <u>Water</u> | <u>Low</u> | <u>High</u> | <u>Date</u> | <u>Violation</u> | <u>Typical Source</u> |
|--------------------------------------|--------------|-------------|--------------|------------|-------------|-------------|------------------|---------------------------------------------------------------------------------------------------------------------------|
| Inorganic Contaminants | | | | | | | | |
| Antimony (ppb) | 6 | 6 | 0.788 | NA | | 2009 | No | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition. |
| Arsenic (ppb) | 0 | 10 | 2.3 | NA | | 2013 | No | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes |
| Barium (ppm) | 2 | 2 | 0.051 | NA | | 2013 | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Fluoride (ppm) | 4 | 4 | 0.28 | NA | | 2013 | No | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Nitrate [measured as Nitrogen] (ppm) | 10 | 10 | 1 | NA | | 2013 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Selenium (ppb) | 50 | 50 | 2.8 | NA | | 2013 | No | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines |
| Sodium (optional) (ppm) | | 230 | 0 | NA | | 2009 | No | Erosion of natural deposits; Leaching |

Microbiological Contaminants

| | | | | | | | | |
|-----------------------------------------|---|---|---|----|--|------|-----|--------------------------------------|
| Total Coliform (positive samples/month) | 0 | 1 | 4 | NA | | 2013 | Yes | Naturally present in the environment |
|-----------------------------------------|---|---|---|----|--|------|-----|--------------------------------------|

Radioactive Contaminants

| | | | | | | | | |
|------------------------|---|----|-----------------|----|--|------|----|-----------------------------|
| Alpha emitters (pCi/L) | 0 | 15 | 4.48992 1925 | NA | | 2009 | No | Erosion of natural deposits |
| Uranium (ug/L) | 0 | 30 | 2.94 | NA | | 2009 | No | Erosion of natural deposits |

| <u>Contaminants</u> | <u>MCLG</u> | <u>AL</u> | <u>Your Water</u> | <u>Sample Date</u> | <u># Samples Exceeding AL</u> | <u>Exceeds AL</u> | <u>Typical Source</u> |
|----------------------------------------------|-------------|-----------|-------------------|--------------------|-------------------------------|-------------------|----------------------------------------------------------------------|
| Inorganic Contaminants | | | | | | | |
| Copper - action level at consumer taps (ppm) | 1.3 | 1.3 | 0.0751178 7 | 2013 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits |
| Lead - action level at consumer taps (ppb) | 0 | 15 | 0 | 2013 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits |

Violations and Exceedances

Total Coliform

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. The monthly sample taken on 5/29/13 came back positive. Four of the 5 repeat samples also came back positive on 5/31/13. The Water Operator flushed and disinfected the system. He took a special sample on 6/5/13 which came back negative.

Unit Descriptions

| Term | Definition |
|------------------------|----------------------------------------------------------------------------------------|
| ug/L | ug/L : Number of micrograms of substance in one liter of water |
| ppm | ppm: parts per million, or milligrams per liter (mg/L) |
| ppb | ppb: parts per billion, or micrograms per liter (µg/L) |
| pCi/L | pCi/L: picocuries per liter (a measure of radioactivity) |
| positive samples/month | positive samples/month: Number of samples taken monthly that were found to be positive |
| NA | NA: not applicable |
| ND | ND: Not detected |
| NR | NR: Monitoring not required, but recommended. |

| Important Drinking Water Definitions | |
|---------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Term | Definition |
| MCLG | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MCL | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| TT | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |
| AL | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| Variances and Exemptions | Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions. |
| MRDLG | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| MNR | MNR: Monitored Not Regulated |
| MPL | MPL: State Assigned Maximum Permissible Level |

For more information please contact:

Contact Name: Veronica Castro
Address:
P.O. Box 453
Ribera, NM 87560
Phone: 575-421-3892
Fax: 575-421-3892
E-Mail: elvallewater@hotmail.com
Website: elvallewateralliance.com